

**RESCIND BOIL WATER NOTICE  
FEBRUARY 23, 2021 at 4:00 pm**

On February 17, 2021, the Texas Commission on Environmental Quality required the City of Marble Falls Public Water System (#0270026) to issue a Boil Water Notice to inform all customers that due to conditions that occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of **February 23, 2021 at 4:00 pm**.

If you have questions concerning this matter, you may contact James Kennedy, Director of Public Works at 830-798-6260 or email [jkennedy@marblefallstx.gov](mailto:jkennedy@marblefallstx.gov).

Due to electrical surges and loss of power during the unprecedented winter storm, the distribution system was depleted due to loss of pressure. The Water Treatment Plants are functioning at full capacity and the distribution system has been flushed and returned to normal levels. Multiple water samples were collected throughout the city and sent to a certified laboratory for bacteriological testing and returned confirming water is safe for consumption.

If a customer, wishes to contact the TCEQ Executive Director, please call (512) 239-4691.