

NOTES:

1. SUBGRADE SHALL BE COMPACTED TO AN OPTIMUM MOISTURE CONTENT, TO 95% AT (+/-)2% MODIFIED PROCTOR DENSITY AS DETERMINED BY ASTM D1557.
2. A MINIMUM OF 4" TOPSOIL SHALL BE REMOVED THROUGHOUT THE IMPACTED AREA PRIOR TO INSTALLATION OF PROPOSED IMPROVEMENTS.
3. CONTRACTOR SHALL ESTABLISH GRASS ON ALL IMPACTED AREAS.
4. THE NON-WOVEN FABRIC SHALL BE OF MEDIUM WEIGHT. CONTRACTOR SHALL PROVIDE A FABRIC SAMPLE TO CITY REPRESENTATIVE FOR APPROVAL.
5. CONTRACTOR SHALL PROVIDE A SAMPLE OF THE CRUSHED GRANITE TO CITY REPRESENTATIVE FOR APPROVAL.
6. RIBBON CURBS SHALL HAVE A CONTRACTION JOINT AT 10' O.C. AND AN EXPANSION JOINT AT 40' O.C. PER ASTM C1752.
7. ALL CONCRETE SHALL BE CLASS "A" CONC.
8. ALL CONSTRUCTION SHALL BE DONE PER CITY OF MARBLE FALLS STANDARDS AND SPECIFICATIONS.


SCALE: NOT TO SCALE



MARBLE FALLS
800 THIRD STREET
MARBLE FALLS, TX 78654
PH: (830) 693-6737

These documents were prepared by,
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017
Engineer's Name PE# Date


Engineer's Signature

SECTION

PAVING

DETAIL NO.

PV-34

TITLE

HIKE & BIKE
TRAIL SECTION (2 OF 2)