



NOTES:

1. SERVICE CONNECTION RISERS SHALL TERMINATE 6' INSIDE THE PROPERTY LINE.
2. THE END OF EACH SERVICE CONNECTION RISER SHALL BE EXTENDED 12" ABOVE FINISH GRADE.
3. EACH SERVICE CONNECTION SHALL BE PLUGGED WATER-TIGHT WITH AN APPROVED CAP OR PLUG.
4. CUT OFF BELL END WHEN USING FERCO COUPLING FOR V.C.P. (FOR EXISTING SERVICES ONLY).
5. FOR P.V.C. INSTALLATIONS, CONNECT TO EXISTING "BELL END" AND CONNECT OPPOSITE END WITH P.V.C. TO P.V.C. KNOCK ON SLEEVE.
6. SOLIDLY TAMP BACKFILL AT LEAST ONE FOOT (1'-0") ABOVE TOP OF PIPE. SERVICES UNDER PAVED AREAS SHALL BE BACKFILLED TO THE SAME SPECIFICATIONS AS SHOWN ON PAVEMENT REPLACEMENT DETAIL.
7. CONTRACTOR SHALL MARK ON A CLEAN SET OF PLANS THE FINAL STATIONING OR DISTANCE AND DIRECTION FROM MANHOLE TO EACH SERVICE LATERAL AND GIVE TO ENGINEER FOR RECORD DRAWING PURPOSES.
8. ANY DEVIATION FROM THESE METHODS SHOULD BE APPROVED BY THE CITY OF MARBLE FALLS PUBLIC WORKS DEPARTMENT.
9. SERVICE LINE MATERIAL SHALL BE P.V.C., SDR-26.
10. SEWER SERVICE SLOPE TO BE 45° OFF THE MAIN PIPE CENTERLINE
11. ALL NON-RESIDENTIAL SERVICE LINES 6" OR GREATER MUST DISCHARGE TO A NEW MANHOLE ON THE MAIN PIPE.
12. ALL NON-RESIDENTIAL DOUBLE SERVICE LINES SHALL BE 8" OR LARGER.

SCALE: NOT TO SCALE



MARBLE FALLS  
800 THIRD STREET  
MARBLE FALLS, TX 78654  
PH: (830) 693-6737

These documents were prepared by,  
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017  
Engineer's Name PE# Date

Engineer's Signature

SECTION  
**WASTEWATER**

DETAIL NO.  
**WW-10**

TITLE  
SERVICE LINE