



BED SANITARY SEWER LINE IN BROWN COLORED CEMENT STABILIZED SAND /MINIMUM CEMENT CONTENT OF 2.5 BAGS OF CEMENT PER CUBIC YARD. CEMENT STABILIZED SAND SHALL BE PLACED 6" ABOVE AND 4" BELOW THE WASTEWATER LINE.

\*ALL CROSSINGS SHALL COMPLY WITH CURRENT TCEQ REQUIREMENTS.

SCALE: NOT TO SCALE



MARBLE FALLS  
800 THIRD STREET  
MARBLE FALLS, TX 78654  
PH: (830) 693-6737

These documents were prepared by,  
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017  
Engineer's Name PE# Date

Engineer's Signature

SECTION

**WASTEWATER**

DETAIL NO.

WW-43

TITLE

PROPOSED WW LINE  
UNDER PROPOSED WATER