



**** NOTE:**

1. SEWER PIPE SHALL BE SDR 21 W/ PRESSURE RATING OF 200 PSI WITH MECHANICAL JOINTS.
2. 1' MIN. SEPARATION, SEPERATE JOINTS AS FAR AS POSSIBLE FROM CROSSING.
3. CENTER ONE 18' MIN. JOINT OF SEWER LINE OVER CROSSING.
4. ALL CROSSINGS SHALL COMPLY WITH CURRENT TCEQ REQUIREMENTS AND IN ACCORDANCE W/AWWA & ASTM STANDARDS.
5. WHEN POSSIBLE, ALL SEWER LINES SHALL BE ROUTED BELOW WATER LINES.

SCALE: NOT TO SCALE



MARBLE FALLS
800 THIRD STREET
MARBLE FALLS, TX 78654
PH: (830) 693-6737

These documents were prepared by,
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017
Engineer's Name PE# Date

Engineer's Signature

SECTION

WASTEWATER

DETAIL NO.

WW-35

TITLE

PROPOSED WW OVER
WATER MAIN CROSSING