

**NOTES:**

1. SUCCESSIVE TEES INTO THE SEWER MAIN SHALL BE SPACED A MINIMUM OF 18" OFFSET AND AT THE CENTERLINE AS SHOWN ON DETAIL "A".
2. THE TOP OF RISER PIPE SHALL BE SET 2' ABOVE FINISHED GRADE.
3. SDR-26 OR SCH-40 CASING REQUIRED FOR ALL PAVEMENT CROSSINGS. CASING SHALL BE AT LEAST TWICE THE DIAMETER OF THE SERVICE. STEEL CASING PIPE REQUIRED FOR JACK AND BORE. LIMITS OF CASING SHOULD EXTEND SIX FEET BEYOND THE EDGE OF PAVEMENT OR BACK-OF-CURB.
4. ANY VARIATIONS ON FITTINGS MUST BE APPROVED BY THE MARBLE FALLS PUBLIC WORKS DEPARTMENT.
5. WET CONNECTIONS TO ACTIVE WASTEWATER FORCE MAINS SHALL BE REQUIRED. SERVICE LEADS 2" IN DIAMETER SHALL USE SMITH-BLAIR 372 ALL STAINLESS STEEL, DOUBLE STUD SERVICE SADDLES FOR WET TAPS TO FORCE MAINS. SERVICE LEADS LARGER THAN 2" IN DIAMETER SHALL REQUIRE SMITH-BLAIR 663 ALL STAINLESS STEEL TAPPING SLEEVES FOR WET CONNECTIONS TO FORCE MAINS.


SCALE: NOT TO SCALE



MARBLE FALLS  
800 THIRD STREET  
MARBLE FALLS, TX 78654  
PH: (830) 693-6737

These documents were prepared by,  
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017  
Engineer's Name PE# Date



Engineer's Signature

SECTION  
**WASTEWATER**

DETAIL NO.  
**WW-27**

TITLE  
LONG NON-RESIDENTIAL FM  
SERVICE LINE SECTION