

NOTES:

1. SUCCESSIVE TEES INTO THE SEWER MAIN SHALL BE SPACED A MINIMUM OF 18" OFFSET AND AT THE CENTERLINE AS SHOWN ON DETAIL "A".
2. THE TOP OF RISER PIPE SHALL BE SET 2' ABOVE FINISHED GRADE.
3. ANY VARIATIONS ON FITTINGS MUST BE APPROVED BY THE MARBLE FALLS PUBLIC WORKS DEPARTMENT.
4. WET CONNECTIONS TO ACTIVE WASTEWATER FORCE MAINS SHALL BE REQUIRED. SMITH-BLAIR 372 ALL STAINLESS STEEL, DOUBLE STUD SERVICE SADDLES SHALL BE REQUIRED FOR SINGLE FAMILY RESIDENTIAL WET TAPS TO FORCE MAINS.


SCALE: NOT TO SCALE



MARBLE FALLS
800 THIRD STREET
MARBLE FALLS, TX 78654
PH: (830) 693-6737

These documents were prepared by,
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017
Engineer's Name PE# Date


Engineer's Signature

SECTION
WASTEWATER

DETAIL NO.
WW-29

TITLE
SHORT RESIDENTIAL FM
SERVICE LINE SECTION