



**NOTES:**

1. FIRE HYDRANT SHALL BE INSTALLED ON SAME SIDE OF ROAD AS WATER MAIN.
2. FIRE HYDRANT SHALL BE INSTALLED PLUMB AND TRUE.
3. ALL FIRE HYDRANT EXTERIORS SHALL BE FACTORY PRIMED AND PAINTED MARBLE FALLS STANDARD COLOR. USING A HIGH GRADE ENAMEL.
4. HEEL AND THRUST BLOCKS TO REST IN UNDISTURBED SOIL.
5. ACCEPTABLE FIRE HYDRANTS ARE:
  - A. MUELLER CENTURION
  - B. AMERICAN DARLING
  - C. CLOW MEDALLION
6. DOUBLE BLUE REFLECTOR "HYE-LITES" BRAND, MANUFACTURED BY PAVEMENT MARKERS INC. TO BE INSTALLED AT CENTERLINE OF STREET PERPENDICULAR TO HYDRANT.

SCALE: NOT TO SCALE



**MARBLE FALLS**  
 800 THIRD STREET  
 MARBLE FALLS, TX 78654  
 PH: (830) 693-6737

These documents were prepared by,  
 or under the supervision of:

ERIC BELAJ 107148 May 31, 2017  
 Engineer's Name PE# Date

*[Signature]*  
 Engineer's Signature

SECTION

**WATER**

DETAIL NO.

**WT-21**

TITLE

PARALLEL FIRE HYDRANT  
 ASSEMBLY (2 OF 2)