



SET POINTS: VALVE SETTINGS SHALL BE DETERMINED BY DESIGN ENGINEER.

NOTE:

1. INSTALL VALVE AS SHOWN WITH WEIGHT OF VALVE FULLY SUPPORTED ON COMPACTED MORTAR SAND BEFORE ADDING WATER TIGHT GROUT OR CEMENT STABILIZED SAND.
2. INSTALL GAUGES TO BE VISIBLE FROM VAULT OPENING.
3. ALL MJ FITTINGS TO INCORPORATE "MEGALUG" RETRAINING GLANDS.

SCALE: NOT TO SCALE



MARBLE FALLS
 800 THIRD STREET
 MARBLE FALLS, TX 78654
 PH: (830) 693-6737

These documents were prepared by,
 or under the supervision of:

ERIC BELAJ 107148 May 31, 2017
 Engineer's Name PE# Date

[Signature]
 Engineer's Signature

SECTION

WATER

DETAIL NO.

WT-25

TITLE

PRESSURE REDUCING VALVE