

BED SANITARY SEWER LINE IN BROWN COLORED CEMENT STABILIZED SAND /MINIMUM CEMENT CONTENT OF 2.5 BAGS OF CEMENT PER CUBIC YARD. CEMENT STABILIZED SAND SHALL BE PLACED 6" ABOVE AND 4" BELOW THE WASTEWATER LINE FOR THE TOTAL LENGTH OF 1 PIPE SEGMENT PLUS 12 INCHES BEYOND THE JOINT AT EACH END.

NOTES:

1. PIPE CENTERED WITH 2' SEPARATION, CENTER CROSSING OVER SEGMENT OF WASTE WATER LINE WHEN POSSIBLE. IF EXISTING WASTE WATER MAIN IS DISTURBED OR SHOW SIGNS OF LEAKAGE NOTIFY ENGINEER IMMEDIATELY.

* ALL CROSSINGS SHALL COMPLY WITH CURRENT TCEQ REQUIREMENTS AND IN ACCORDANCE WITH AWWA AND/OR ASTM STANDARDS.


SCALE: NOT TO SCALE



MARBLE FALLS
800 THIRD STREET
MARBLE FALLS, TX 78654
PH: (830) 693-6737

These documents were prepared by,
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017
Engineer's Name PE# Date


Engineer's Signature

SECTION

WATER

DETAIL NO.

WT-33

TITLE

WASTEWATER LINE UNDER
WATER MAIN CROSSING