



NOTES:

1. AUTHORIZED SERVICE LINE MATERIAL (2" DIAMETER): 2" MUNICIPEX, 250 PSI
 - A. BLUE MUNICIPEX (2" DIAMETER) 250 PSI - MAIN LINE TO 2" TEE (FORD T444-774-AWT-NL).
 - B. TYPE "K" COPPER (1" DIAMETER) - 2" TEE (FORD T444-774-AWT-NL) TO METER
2. ANGLE STOP SHALL BE 1" MINIMUM, FORD BRASS ONLY.
3. 1" ANGLE STOPS WITH 3/4" VALVES SHALL NOT BE PERMITTED.
4. MULTIPLE SERVICE/METER INSTALLATIONS OF MORE THAN 4 METERS PER SERVICE AND SERVICE LINES LARGER THAN 2" IN DIAMETER SHALL BE HANDLED ON AN INDIVIDUAL BASIS.
5. ANGLE STOPS 1 1/2" AND 2" IN SIZE SHALL BE PROVIDED WITH BOTH A LOCKING CAP AND METER FLANGE.
6. THERE SHALL BE A 6" ENVELOPE OF SAND AROUND ALL SERVICE AND CASING PIPE. COMPACT BACKFILL ON LONG SERVICES UNDER ROADWAYS PER SPECIFICATIONS.
7. CASING REQUIREMENTS FOR SERVICE LINES CROSSING ROADWAYS SEE DETAIL LONG SINGLE & DOUBLE WATER SERVICE SECTION.
8. ANY VARIATIONS ON FITTINGS MUST BE APPROVED BY THE MARBLE FALLS PUBLIC WORKS DEPARTMENT.
9. METER BOX TO BE SOLID PLASTIC WITH BLACK CAST IRON LID AND FLIP LID FOR METER READING. MODEL NO. 36 MANUFACTURED BY MID-AMERICAN RESEARCH CHEMICAL CORPORATION OR APPROVED EQUAL.

SCALE: NOT TO SCALE



MARBLE FALLS

800 THIRD STREET
MARBLE FALLS, TX 78654

PH: (830) 693-6737

These documents were prepared by,
or under the supervision of:

Kacey Cubine Paul 120200 June 6, 2023
Engineer's Name PE# Date

Engineer's Signature

SECTION

WATER

DETAIL NO.

WT-6

TITLE

DOUBLE SERVICE PLAN