



NOTES:

1. SUCCESSIVE TAPS INTO THE WATER MAIN SHALL BE SPACED A MINIMUM OF 18" OFFSET AND AT THE CENTERLINE AS SHOWN ON DETAIL "A".
2. THE TOP OF METER BOX SHALL BE SET 1" ABOVE FINISHED GRADE.
3. AUTHORIZED SERVICE LINE MATERIAL:
 - A. TYPE "K" COPPER (1" DIAMETER) FROM 2" X 1" BUSHING TO METER BOX.
 - B. BLUE MUNICIPEX (1" - 2" DIAMETER) 250 PSI - FROM MAIN TO 2" X 1" BUSHING.
4. ROTATE THE CORPORATION STOP SO THAT THE OPERATING NUT IS ACTUATED FROM THE VERTICAL POSITION RATHER THAN THE HORIZONTAL.
5. SERVICE LINES SHALL BE CONTINUOUS FROM CORPORATION STOP TO 2" BRASS 90° BEND OR 2" BRASS TEE WITH NO FITTINGS IN BETWEEN.
6. SERVICE CASING SHALL NOT BE INSTALLED BY WATER JETTING UNDER ROADWAY.
7. CASING REQUIRED FOR ALL PAVEMENT CROSSINGS. 4" SH-40, BLUE, WHITE, OR BLACK, REQUIRED FOR OPEN-CUT. GALVANIZED CASING PIPE REQUIRED FOR JACK AND BORE. LIMITS OF CASING SHOULD EXTEND SIX FEET BEYOND THE EDGE OF PAVEMENT OR BACK-OF-CURB.
8. THERE SHALL BE A 6" ENVELOPE OF 3/8" ROCK OR APPROVED BEDDING SAND AROUND ALL SERVICE AND CASING PIPE. COMPACT BACKFILL ON LONG SERVICES UNDER ROADWAYS PER STANDARD DETAIL W03 OR W04.
9. ANY VARIATIONS ON FITTINGS MUST BE APPROVED BY THE MARBLE FALLS PUBLIC WORKS DEPARTMENT.
10. METER BOX TO BE SOLID BLACK PLASTIC WITH BLACK CAST IRON LID AND FLIP LID FOR METER READING. MODEL NO. MB-16L OR LL MANUFACTURED BY RHINO WITH HINGED READER LID OR APPROVED EQUAL.
11. CORPORATION STOPS, ANGLE STOPS AND OTHER BRASS FITTINGS SHALL BE MANUFACTURED BY FORD, OR APPROVED EQUAL.

SCALE: NOT TO SCALE



MARBLE FALLS

800 THIRD STREET
 MARBLE FALLS, TX 78654

PH: (830) 693-6737

These documents were prepared by,
 or under the supervision of:

Kacey Cubine Paul 120200 June 6, 2023
 Engineer's Name PE# Date

Engineer's Signature

SECTION

WATER

DETAIL NO.

WT-7

TITLE

DOUBLE SERVICE SECTION