

MATERIALS LIST

METER SIZE

A. SERVICE CLAMP FOR CONNECTION- REQUIRED ON ALL _____ (1 1/2") PLASTIC AND ASBESTOS CEMENT PIPE AND ALL IRON PIPE 300 mm (12") AND SMALLER	(2")
B. CORPORATION STOP - SERVICE PIPE OUTLET _____ (1 1/2")	(2")
C. SERVICE PIPE _____ (1 1/2")	(2")
D. COUPLING: SERVICE PIPE TO MALE I.P.T. _____ (1 1/2") (COMPRESSION FITTING)	(2")
E. BALL VALVE. SEE SPL WW 275 _____ (1 1/2")	(2")
F. TEES, BRASS _____ (1 1/2"x1 1/2"x1")	(2"x2"x1")
G. CLOSE-NIPPLE, BRASS _____ (1 1/2")	(2")
H. ANGLE METER STOP, FEMALE I.P. THREAD INLET X _____ (1 1/2") FLANGE OUTLET	(2")
I. WATER METER LENGTH WITH GASKETS _____ (13 1/2")	(17 3/4")
J. FLANGE, BRASS; FEMALE I.P. THREAD _____ (1 1/2")	(2")
K. NIPPLES, BRASS _____ (1 1/2"x8")	(2"x8")
L. BALL VALVE _____ (1 1/2")	(2")
M. NIPPLES, BRASS _____ (1"x5")	(2"x5")
N. 90 DEGREE ELBOWS, BRASS _____ (1 1/2")	(2")
O. NIPPLES, BRASS _____ (1 1/2"x3")	(2"x3")
P. CURB STOP, BRASS, FEMALE I.P. THREAD BOTH ENDS _____ (1 1/2") WITH LOCK NUTS	(2")
Q. COUPLINGS, BRASS, SERVICE PIPE TO MALE THREAD _____ (1 1/2")	(2")
R. SERVICE PIPE _____ (1 1/2")	(2")
S. RECTANGULAR METER BOX. _____ (1 1/2")	(2")
T. METER BOX MSBCF 1730-12, METER BOX LID 32131701 FROM EAST JORDAN IRON WORKS, INC. (SUPPLIER/MANUFACTURER).	
U. RECTANGULAR BOX FOR CUSTOMER'S CUT-OFF VALVE _____ (12"x17"x12") (AND PRV WHEN REQUIRED). DFW #D1200 300 mm X 425 mm X 300 mm (12" X 17" X 12")	(2")
V. CUSTOMER'S BALL VALVE _____ (1 1/2")	(2")

NOTES:

1. DRAWING NOT TO SCALE FOR CLARIFICATION OF DIMENSIONS.
2. ADOPTED FROM CITY OF AUSTIN 520S-13.

SCALE: NOT TO SCALE



MARBLE FALLS
800 THIRD STREET
MARBLE FALLS, TX 78654
PH: (830) 693-6737

These documents were prepared by,
or under the supervision of:

ERIC BELAJ 107148 May 31, 2017
Engineer's Name PE# Date

Eric Belaj
Engineer's Signature

SECTION

WATER

DETAIL NO.

WT-10

TITLE

SINGLE 1.5" TO 2" SERVICE
MATERIAL LIST